

Stage 2 DBPR Important Dates				
Water System Schedule	Water System Population	Submit Compliance Monitoring Plan By:	Compliance Begins for Quarterly Monitoring*	Compliance Begins for Annual Monitoring
1	Serving 100,000 or more	October 31, 2011	1 st Quarter 2012	Peak Historical Month in 2012
2	Serving between 50,000 and 99,999	December 31, 2011	2 nd Quarter 2012	Peak Historical Month in 2012
3	Serving between 10,000 and 49,999	October 1, 2012	2 nd Quarter 2013	Peak Historical Month in 2013
4	Serving less than 10,000	October 1, 2012	3 rd Quarter 2013	Peak Historical Month in 2013

* Systems that conducted the IDSE must start per compliance monitoring per their IDSE Report.

Stage 2 Monitoring Requirements Ground Water Systems			
Source Type	Population	Compliance Monitoring	
		FREQ ¹	TOTAL ²
GW or GWP	<500	Peak Month	2 sites
GW or GWP	500 – 9,999	Peak Month	2 sites
GW or GWP	10K – 99,999	Every 90 Days	4 sites
GW or GWP	100K – 499,999	Every 90 Days	6 sites
GW or GWP	≥ 500K	Every 90 Days	8 sites

¹ All systems must monitor during month of highest DBP concentrations.
² All systems must take dual a sample set (TTHM and HAA5) at each site.

Stage 2 Monitoring Requirements Surface Water Systems			
Source Type	Population	Compliance Monitoring	
		FREQ ¹	TOTAL ²
SW or SWP	<500	Peak Month	2 sites
SW or SWP	500 – 3,300	Every 90 Days	2 sites
SW or SWP	3,301 – 9,999	Every 90 Days	2 sites
SW or SWP	10K – 49,999	Every 90 Days	4 sites
SW or SWP	50K – 249,999	Every 90 Days	8 sites
SW or SWP	250K – 999,999	Every 90 Days	12 sites
SW or SWP	1M– 4,999,999	Every 90 Days	16 sites
SW or SWP	≥ 5M	Every 90 Days	20 sites

¹ All systems must monitor during month of highest DBP concentrations.
² All systems must take dual a sample set (TTHM and HAA5) at each site.

- ### Selecting Stage 2 DBPR Sites:
- Downstream of tanks
 - Dead ends, but prior to last customers and prior to last hydrant or blowoff
 - Hydraulic dead ends and mixing zones
 - Downstream of booster chlorination
 - Sites with difficulty maintaining residual
 - Areas with low water use and low chlorine
 - Areas of high historic TTHM and/or HAA5 levels

Certified Lab Analysis

Total Trihalomethanes (TTHMs) - four analytes	Haloacetic Acids (HAA5s) - 5 analytes
• Bromoform	• <u>D</u> ibromoacetic Acid
• Bromodichloromethane	• <u>D</u> ichloroacetic Acid
• Chloro <u>dibrom</u> omethane	• Monobromoacetic Acid
• Chloroform	• Monochloroacetic Acid
	• Tichloroacetic Acid

Notes:

- Contact a certified lab for the sample kit which contains multiple bottles for each monitoring site.
- Lab reports must contain the Public Water Supply Name and ID number and the sample locations.

- ### Sending Required Info to LDHH
- Systems must send Stage 2 Compliance Monitoring Plan to LDHH for approval, in addition to:
 - Monitoring Plan Changes
 - TTHM and HAA5 Data (certified lab report)
 - Operational Level Reports
 - Label your Map with PWS Name and PWS ID
 - Send all the above to:
 - » DBP Compliance Manager
 - » DHH-OPH Engineering Services
 - » P.O. Box 4489
 - » Baton Rouge, LA 70821
- 

Stage 2 DBPR – Recordkeeping Requirements

Maintain the following for:

- Initial Distribution System Evaluation (IDSE) Reports – 10 years
- Monitoring Plans – as long as it applicable
- Chemical (*i.e.*, TTHM-HAA5) data – 10 years
- LDHH correspondence (*i.e.*, violation/monitoring letters, etc.) – 3 years
- Operational Evaluation Level (OEL) Reports – 10 years
- Public Notices – 3 years
- Consumer Confidence Reports – 3 years

Is My System in Compliance with the Stage 2 DBPR?

If my water system is required to:

- Monitor **yearly**, I am in compliance if sample result < MCL for **every sample site**
- Monitor **every 90 days**, I am in compliance if the Locational Running Annual Average calculated as $(Q1 + Q2 + Q3 + Q4)/4 < \text{MCL}$ for **every sample site**

TTHM MCL = 0.080 mg/L

HAA5 MCL = 0.060 mg/L

Operational Evaluation Level Report: Is Required **Every** time when...

My water system is required to monitor every 90 days and **at any** site:

$$\frac{Q_1 + Q_2 + 2Q_3}{4} > \text{MCL}$$

- where

Q₃ = current quarter result multiplied by 2

Q₂ = previous quarter result

Q₁ = quarter before previous quarter result

Operational Evaluation Level Report: Is **NOT** required if...

The OEL Report is not required if:

- ✓ ALL **individual** sample results (this means **do NOT average**) for every quarter for ALL sites are below the MCL

TTHM MCL < 0.080 mg/L

HAA5 MCL < 0.060 mg/L

Operational Evaluation Level Report: What to Write and When to Submit?

- Submit the OEL report within 90 days of OEL exceedance
- The OEL Report must describe **how to reduce high DBP levels** and **how each** of the following may have **affected DBP levels**:
 - Storage tank operations
 - Excess storage capacity
 - Distribution system flushing
 - Treatment changes
 - Changes in sources or source water quality
 - Any issues that may contribute to TTHM and HAA5 formation

Stage 2 Questions?

LDHH Contact



Caryn Benjamin
225-342-6157

Caryn.benjamin@la.gov

DBP Compliance Manager
225-342-7499

EPA Region 6 Contact



Jatin H. Mistry
214-665-7483

Mistry.jatin@epa.gov